Panasonic

Test Report

ziaino®

ziaino® inhibits activity of adhered Influenza A virus (Type A influenza) by over 99% in 1 hour

Test outline

(1)Testing organisation: Kitasato Research Center for Environmental Science

(2)Test subject: Adhered Influenza A virus (H3N2)

(3)Test volume: Approx. 25m^3 laboratory (3.3m×3.5m×2.2m)

(4)Test result: Inhibited over 99% in 1 hour

(5)Report No.: Kitakanhatsu 2015-0032

Test ambient

Approx. 25m^3



Test result

Influenza A virus (H3N2)



20157032／2015_0032

パナソニックエコシステムズ株式会社 殿

試 験 報 告 書

業務用空間清浄機「JML30」による付着ウイルスの抑制性能評価試験（25 m³ 空間）

北環発 2015_0032 号
2015 年 9 月 16 日

神奈川県相模原市南区北里 1 丁目 15 番 1 号
一般財団法人 北里環境科学センター
理 事 長　伊 藤 俊 洋

試験内容を公表する際は、結果の表記等について専門的な立場から確認させていただいております。なお、確認目的と申込様式は、ホームページに収載しております。
（http://www.kitasato-e.or.jp/?page_id=87）