Panasonic

Test Report

ziaino®

ziaino® inhibits activity of adhered *Streptococcus pneumoniae* (Streptococcus pneumoniae infection) by over 99% in 2 hours

Test outline

(1)Testing organisation: Kitasato Research Center for Environmental Science

(2)Test subject: Adhered *Streptococcus pneumoniae*

(3)Test volume: Approx. 25m^3 laboratory (3.3m×3.5m×2.2m)

(4)Test result: Inhibited over 99% in 2 hours

(5)Report No.: Kitaseihatsu 2016-1129

Test ambient

Approx. 25m^3



Test result

Streptococcus pneumoniae



2016_41129

パナソニックエコシステムズ株式会社 殿

試 験 報 告 書

業務用空間清浄機「JML30」による

付着菌（肺炎レンサ球菌）の抑制性能評価試験

（25 m^3 空間）

北生発 2016_1129 号

2016 年 9 月 1 日

神奈川県相模原市南区北里 1 丁目 15 番 1 号

一般財団法人 北里環境科学センター

理 事 長　伊 藤 俊 洋

試験内容を公表する際は、結果の表記等について専門的な立場から確認させていただいております。

なお、確認目的と申込様式は、ホームページに収載しております。

（http://www.kitasato-e.or.jp/?page_id=87）