Panasonic

Test Report

ziaino®

ziaino® inhibits activity of adhered *Staphylococcus aureus* by over 99% in 12 hours

Test outline

(1)Testing organisation: Kitasato Research Center for Environmental Science

(2)Test subject: Adhered *Staphylococcus aureus*

(3)Test volume: Approx. 70m^3 laboratory (5.3m×5.3m×2.5m)

(4)Test result: Inhibited over over 99% in 12 hours

(5)Report No.: Kitaseihatsu 2019-0058

Test ambient

Approx. 70m^3



Test result

Staphylococcus aureus



2019_0058

パナソニック エコシステムズ株式会社 殿

試 験 報 告 書

特定付着菌およびウイルスの

抑制性能評価試験

（18 畳空間）

北生発 2019_0058 号

2019 年 6 月 2 日

神奈川県相模原市南区北里 1 丁目 15 番 1 号

一般財団法人 北里環境科学センター

理 事 長　伊 藤 俊 洋

試験内容を公表する際は、結果の表記等について専門的な立場から確認させていただいております。

なお、確認目的と申込様式は、ホームページに収載しております。

（http://www.kitasato-e.or.jp/?page_id=87）