

Test Report


An air conditioner equipped with nanoe™ inhibits activity of adhered staphylococcus aureus by 99.1% in 8 hours

Test outline


- (1) Testing organisation: Japan Food Research Laboratories
- (2) Test subject: Adhered staphylococcus aureus
- (3) Test volume: Approx. 23 m³ laboratory (3.6×2.7×2.4m)
- (4) Test result: Inhibited 99.1% in 8 hours
- (5) Report No.: 13044083003-01

Test ambient

Approx. 23 m³



Test result





Japan
Food
Research
Laboratories

第 13044083003-01 号 page 1/3

2013年(平成25年)06月14日

試験報告書

依頼者 パナソニック株式会社

一般財団法人

日本食品分析センター

東京都渋谷区元代々木1-52番1号



検体 nanoe+送風装置

表題 除菌効果試験

2013年(平成25年)05月31日当センターに提出された上記検体について試験した結果をご報告いたします。

本報告書を他に掲載するときは当センターの掲載規約をお守りください。

一般財団法人

日本食品分析センター